



# Automated Fault Detection With PQ Monitors

---

Theo Laughner, PE

Sr. Program Manager of Power Quality

Acknowledgements: Anthony Murphy, PE

October 12, 2015



# Presentation Outline

- Background
- Case Studies (5)
- Needs
- Tools
- Conclusion



# Background

- ~1200 Metering Devices
  - DFR
  - PQ Meter
  - Revenue Meter w/PQ Capability
- Multiple Download Frequencies
  - Daily
  - Hourly
  - Sub-Hourly



# Data Quantity By The Numbers...

## DFR

- 251 Devices
- ~80 Channels / Dev
- ~3 MB / Event
- 1 Event / Day
- > 750 MB / Day
- > 20k Channels

## PQ Meter

- 1069 Devices
- 300 Channels / Dev
- ~3 MB / Day
- 144 Points / Day
- > 3200 MB / Day
- > 320k Channels

# Cap Bank Switch Failure aka “The Good”




Pre-insertion inductors mounted on 138-kV Vertical-Break Style Mark V Circuit-Switcher.

An S&C Mark V switch is opened to take the Cap Bank Off Line.

About 6 cycles later the breaker protecting the bank trips.


PQ asked to investigate why...





# The Good (Continued)...

Cap Bank - 09/05/2012 20:24:27.1454





# The Good (Continued)...

- No flashover occurred (luck).
- PQ Group suggested low SF-6 as likely reason for the failed open attempt.
- Field personnel found that the B-Phase bottle was empty.

# Mark V Capacitor Bank Switcher and SF-6 Gas Indicator





# PT Failure - aka “The Bad”







# The Bad (Continued)...

A PQ monitor receives voltage inputs from the 161kV Main Bus VTs. The PQM recorded a series of voltage transients indicating arcing on B-phase in the minutes prior to the VT failure on **01/03/2013**. These incipient waveforms were recorded from **13:29CT** up until failure at **13:53CT**.

13:30



13:45







# The Bad (Continued)...

Waveforms with similar transient disturbances on the B-phase voltage indicating arcing were also recorded on 12/20/2012 from 07:04CT to 07:05CT and on 12/22/2012 from 15:17CT to 15:18CT. Thus, indications of a problem existed up to two full weeks before the VT failure.

12/20/2012 7:04




12/22/2012 15:17





# Transmission Lines Unknown Events aka “The Ugly”



CG Fault

Insulation  
Breakdown



# The Ugly (Continued)...

Date	Time	Cause
Tue, 04/23/13	08:55:14.131CT	Unknown
Thu, 07/21/11	05:40:47.367CT	Unknown
Tue, 02/22/11	01:48:00.450CT	Unknown
Sat, 08/14/10	00:14:41.028CT	Unknown
Wed, 02/24/10	05:31:57.753CT	Unknown
Wed, 01/20/10	09:00:44.350CT	Unknown



# The Ugly (Continued)...

Date ▼	Time ▼	Cause ▼	Phase ▼
Tue, 04/23/13	08:55:14.131CT	Unknown	C
Thu, 07/21/11	05:40:47.367CT	Unknown	C
Tue, 02/22/11	01:48:00.450CT	Unknown	C
Sat, 08/14/10	00:14:41.028CT	Unknown	A
Wed, 02/24/10	05:31:57.753CT	Unknown	C
Wed, 01/20/10	09:00:44.350CT	Unknown	C



# The Ugly (Continued)...

Date	Time	Cause	Phase	Structure A	Structure B	Fault Av
Tue, 04/23/13	08:55:14.131CT	Unknown	C	135	132	
Thu, 07/21/11	05:40:47.367CT	Unknown	C	129	125	
Tue, 02/22/11	01:48:00.450CT	Unknown	C	129	128	
Sat, 08/14/10	00:14:41.028CT	Unknown				
Wed, 02/24/10	05:31:57.753CT	Unknown	C	139	121	
Wed, 01/20/10	09:00:44.350CT	Unknown	C	133	121	


Outlier

There appears to be a problem between Structure 127 and 134!

Field Inspection Reveals 2 Broken Insulators.



# The Weird!




100 MW Oscillations  
detected across Eastern  
Part of Tennessee.

Observed at Hydro and  
Nuclear units at same  
time.



# The Weird! (Continued)




PQ monitors show a minimal impact to voltage (< 5% of nominal).

No devices “triggered”, because there was no “fault” on the system.



# The Weird! (Continued)




What if we developed an algorithm to detect increased PST levels when there was not any indication of a fault on the system?

Then we could alarm on that and make operators aware of this area-wide issue!



# The Headscratcher...



The relay is set to trip when four elements in the same string fail but it is actually tripping when only two elements fail due to the voltage unbalance making it appear as though two additional elements had also failed.

Why was there a 2hr 8min delay between the 2nd element failure and the bank trip?

The relay is set to trip when 4 elements in same string fail. However, relay trips with only the 2nd element failure.

Voltage unbalance makes it appear as though two other elements had also failed.




# The Headscratcher (Continued)...

Issues that influence cap bank imbalance:


- Impedance
  - Temperature
  - Tolerance
- Voltage Imbalance

Could we make a system that incorporates all of these factors to assess the health of the system?





# The Headscratcher (Continued)...





# Needs



- Automated mechanism to analyze data.
- Distill “interesting events” to the top.
- An interesting event database that captures all relevant information about a given event.

Weather  
System Conditions  
SCADA Data  
System Model  
PMU Data  
DFR / PQ  
Historical Performance



# Tools

To address these concerns, two platforms have been developed: openXDA and PQ Dashboard.





# openXDA


- OpenXDA is an extensible platform for performing analytics on waveform data.
- The waveform data can come from a variety of sources: digital fault recorders, relays, power quality monitors, etc.
- After analysis an email is sent letting relevant users know what has happened.

# Sample Email

The email quickly alerts staff to the fact there was an issue.

A variety of algorithms are run on the data and a summary of them is shown.

A link to a more detailed page is provided.





# Detailed Web Page

## Fault Location Reports


Fault Inception Time: 2014-12-15 07:08:39.0354343

Fault Duration: 1.98 cycles / 32.87 ms

Fault Type: BN

Location:

Nearest Structure:



Line Parameters:	Pos-Seq Imp (LLL, LLLG, LL, LLG)				Zero-Seq Imp				Loop Imp (LG)			
Length (Mi)	Z1 (Ohm)	Ang (Deg)	R1 (Ohm)	X1 (Ohm)	Z0 (Ohm)	Ang (Deg)	R0 (Ohm)	X0 (Ohm)	ZS (Ohm)	Ang (Deg)	RS (Ohm)	XS (Ohm)
62.9	35.978	86.218	2.3750	35.9000	126.002	71.768	39.4250	119.6750	65.502	77.011	14.7250	63.8250
Per Mile	0.572	-	0.0378	0.5707	2.003	-	0.6268	1.9026	1.041	-	0.2341	1.0147

Fault Details:	Algorithm	Largest Current Distance	Max Distance	Min Distance	Avg Distance	Deviation
	Simple	16.480	26.264	16.374	17.059	1.301
	Reactance	-15.301	-15.126	-24.205	-15.839	1.150
	Takagi	-15.209	-15.002	-24.394	-15.845	1.196
	ModifiedTakagi	-14.669	-14.341	-23.249	-15.168	1.121
	Novosel	-15.074	-14.909	-24.476	-15.809	1.237

History:	Time	Type	Distance (min/max)
	2015-04-16 14:04:40.1862010	AB	14.83 - 17.09
	2015-04-16 12:18:41.3104010	BC	22.73 - 23.62
	2015-03-20 18:43:07.1751676	BN	11.23 - 11.23
	2014-12-19 14:06:28.2281676	ABC	11.11 - 46.82
	2014-12-19 14:06:28.2281676	ABC	38.33 - 38.33
	2014-12-15 07:08:39.0354343	BN	16.48 - 16.48
	2014-12-15 07:08:21.5727676	BN	19.30 - 19.30

**Analysis:**  
A fault has occurred on this line of type BN: 3 times or 60.00 % of the time.  
A fault has occurred on this line in this area: 3 times or 60.00 % of the time.

The detailed web report shows:

- ✓ Picture of the structure
- ✓ GIS map
- ✓ Line parameters
- ✓ Historical event analysis
- ✓ Links to other relevant information (Drawings)



# open PQ Dashboard

- The dashboard provides visualizations to quickly convey the location of a variety of issues.
- Provides displays that summarize alarm types for various time windows: day, month, etc.
- Provides statistical process control of trended quantities for a given site to emphasize abnormal conditions.
- Provides waveform data for a given event.



Grid indicating sites with issues over timeframe selected.

Historical performance of system is shown.

Links to individual station/data is available.




# Dashboard (Continued)

Geographic Information System (GIS) view.

Map indicating sites with issues over timeframe selected.

Heat map highlights areas with the most potential issues.






# Dashboard (Continued)

Waveform viewer.

Provides web based viewing of waveform data and the resulting fault calculations.



# Development Under Way

- Validation Of Data
- Cap Bank Health Assessment
- Dashboard Enhancements



# Conclusions

- Valuable Information Buried In Data
  - We could be proactive!
  - Save PTs, Cap Banks and Customer Interruptions
- Automated Analysis Is Necessary
  - Too Much Data To Perform Manually
- Automated Analysis Is Here
  - Fault Location Ready
  - Additional Algorithms for “Interesting Events” Need To Be Developed



Questions?

