



21, rue d'Artois, F-75008 PARIS
http : //www.cigre.org

CIGRE US National Committee 2016 Grid of the Future Symposium

Automated Fault Location Analysis - Data Gathering Assessment

C. R. Black
Southern Company
USA

M. Behe
FirstEnergy Corp
USA

G. Wilson
Southern Company
USA

P. T. Myrda
Electric Power Research Institute
USA

SUMMARY

Utilities face significant challenges in locating faults on 110-138Kv systems that are heavily tapped with industrial customers and substations. Typically faults on these circuits do result in customer outages that impact company performance metrics. In order to further reduce the outage duration utilities need to locate the faults more quickly.

One company has developed a process that assists the protection engineer in determining where that faults may be. They accomplish this by using a macro that “slides” the fault all along the various taps on the circuit and identifies the location(s) that match the measured fault current. This process helps but still requires many manual steps and also calling out a protection engineer in the middle of the night.

If one could automate the process completely, then substantial time could be saved. One company in the USA is undertaking the necessary steps to achieve this complete automation. The major steps included capturing and categorizing the fault magnitude and type, identifying significant nearby assets that would impact the fault duty such as line or transformer outages and then executing the macro and finally identifying the fault locations on a geospatial map of the affected area.

KEYWORDS

Fault Location, Automation, Customer Outages

All pages after title page must start from this line, i.e. 1" (2, 5 cm) margin from the top (Times or Helvetica, size 11 or 12). Pages will be automatically numbered.

Problem Statement

Southern Company and FirstEnergy in the United States desire to improve the accuracy and speed of their fault location process especially for the 115-kV system, which is heavily tapped with industrial customers and substations. The Fault Location team had addressed almost all of the elements that have a major impact on the outage duration metric. The primary remaining factor was the need to call out staff to run the fault-location program.

Objective

The overall objective of this effort is to reduce the time to determine where a fault has occurred with sufficient certainty to allow operations staff to begin the process to sectionalize the 115-kV transmission network and begin restoring customers in areas not directly affected by the faulted line section. The expectation is that by automating the analysis, the time previously spent in the off-hours shifts to locate a protection engineer, provide him or her with the needed information, and then perform the analysis would be greatly reduced. This time reduction will improve the performance metrics associated with outage time.

Approach

There is a significant difference between the approaches used to gather the fault information from the field by the two companies. In simple terms, one company uses a "pull" model while the other uses a "push" model. The "pull" model is based on a system operator initiating the process after an event has occurred by enabling a point in SCADA at the relevant stations. This then enables the process to remotely connect to each site and gather the data from each device based on information contained in a reference table. This table previously captured the relationship between the relays and the lines that are associated with them. Once the data is acquired, the process to extract the relevant data and locate the fault begins.

The "push" model monitors a master fault record table and when an event occurs on a line it sees a new record in the master table and begins the process. Once this process gathers the relevant data the process is basically the same as the "pull" model.

The first step in the automation plan was documenting the existing manual process. Figure 1 shows the relevant process steps for the "pull" model while Figure 2 shows the relevant process steps for the "push" model. The process flow has two paths through it and requires the creation of a new table. The first path identifies the parameters of the fault such as fault type and magnitude. The other path determines what network changes are required to accurately represent the grid elements that are out of service in the vicinity of the fault. The new table was developed to essentially "connect" the operations' field data historian with the fault study program.




Figure 1
Master fault record table – Pull Model




Figure 2
Fault location process flow – Push Model

The fault location process begins with monitoring the Master Fault Record table as shown in Figure 3 for new fault records arriving. Specifically, the monitor will look for faulted lines because it is not a trivial task to determine if the fault event relates to a line or transformer. A

watch-dog program will monitor this table for the arrival of relevant fault records and then initiate the process.




Figure 3
Master fault record table

For the fault parameter path, the following parameters need to be determined from the fault record:

Fault Time, used in the report text and file name. Use 'NA' if no time is available.

Bus Number for the "From" bus on the Monitored Line.

Bus Number for the "To" bus on the Monitored Line.

Circuit Number for the Monitored Line.

Bus Number for the "From" bus on the Faulted Line.

Bus Number for the "To" bus on the Faulted Line.

Circuit Number for the Faulted Line.

Fault Type:

PHASE_1_2,PHASE_1_2_G,PHASE_1_G,

PHASE_2_3,PHASE_2_3_G,PHASE_2_G,

PHASE_3_1,PHASE_3_1_G,PHASE_3_G,

THREE_PHASE

Fault Current Magnitude, in amps.

Monitored phase/value (1='Phase 1', 2='Phase 2', 4='Phase 3', 8='Residual').

Once these parameters are gathered from the fault record, the process will automatically generate the Flparam.mac file. (See Figure 3) This file is one of two input files used by the fault-location macro run against fault study program.

```
Sample Flparam.mac file

This file is used to load the parameters for running a fault location.

% The parameters are entered into the array "fl_inputs" as follows:
%
% 1 (string) : Fault Time, used in the report text and file name. Use 'NA' if no time is
available
% 2 (number) : Bus Number for the "From" bus on the Monitored Line
% 3 (number) : Bus Number for the "To" bus on the Monitored Line
% 4 (number) : Circuit Number for the Monitored Line
% 5 (number) : Bus Number for the "From" bus on the Faulted Line
% 6 (number) : Bus Number for the "To" bus on the Faulted Line
% 7 (number) : Circuit Number for the Faulted Line
% 8 (string) : Fault Type
% PHASE_1_2,PHASE_1_2_G,PHASE_1_G,
% PHASE_2_3,PHASE_2_3_G,PHASE_2_G,
% PHASE_3_1,PHASE_3_1_G,PHASE_3_G,
% THREE_PHASE
% 9 (number) : Fault Current Magnitude, in amps
% 10 (number): Monitored phase/value (1='Phase 1', 2='Phase 2', 4='Phase 3', 8='Residual')
```

Figure 4
Sample content description of Flparam.mac file

The other path requires the development of a process to “crawl” through the fault study program database to determine the connectivity to the next 2 “Real” busses in the network. This allows the identification of grid elements that are out of service near the fault. The purpose is to develop a listing of relevant network elements related to the fault and then to determine their state at the time of the fault. A new table that links fault study program to the field historian is needed to build this linkage. From this table, the state of the network elements can be established.

Once the state of the network is established, the result will be passed to the Network Changes Developed step where the file NetworkChanges.mac will be created. As can be seen in Figure 5, the changes consist of opening of branches or breakers, taking a generator out of service, or changing the state of a bus tie or switch.

- %% Examples of Network Change command syntax
- %%Open a branch/breaker
- nc opn 4 6005 1 x
- %%Outage a generator
- nc outage_shunt 5507 1 x
- %%Close a normally-open bus-tie/switch
- nc close_tie 41856 41384
- return

Modify each section based on pre-fault state

Figure 5
Example network changes

Once the above steps are completed, the process updates the fault study program.cfg file as needed and runs Wfault study program.exe to locate the fault. Once completed, the process outputs its results and will distribute output to the appropriate staff.

Data Integration

The integration of the database within fault study program used for the fault study model and the current state of the grid is critical to the success of this process. This requires the development of a new database table that maps the fault study program bus names to the associated EMS bus. The database was created and an automated historian script was developed that allowed elements in the database to be queried, based on their relationship to the facility in the relay fault record.

Challenges/Solutions

There were a few challenges in this task. The first was to properly identify the fault records that needed to be analyzed because more than one record may come in after a fault occurs. Properly discriminating among the fault records to eliminate false process triggers is challenging and requires additional work.

Another challenge was linking the fault study program branches and bus names to the actual EMS names so that the state of the grid elements could be determined. As stated previously, this requires the creation of a new table that needs to be maintained as the grid changes through physical grid modifications.

Analytic

The actual analytic, in this case - a fault location macro run using the fault study program fault study tool, was already in place but was run as a manual process. One simple function that was developed is a watch-dog program that monitored the Master Fault Record Table for fault records related to lines or transformers. Developing this monitor to properly discriminate between faults and other events is another critical factor in the success of the effort.

Results

This process is still in development and additional steps are needed to get the script that has been developed to initiate the executable that queries this fault database. Work remains to complete this process.

BIBLIOGRAPHY

- [1] Southern Company Transmission Modernization Demonstration: Transmission Monitoring, Diagnostics, and Visualization Tool, EPRI Product ID 3002006920, March 2106
- [2] Automated Fault Location Analysis, PAC World – Slovenia, June 2016, Clifton Black, Glenn Wilson, Paul Myrda