

# **BOLD™**

## **System and Performance Considerations**

---

**Nick Koehler, P.E.**  
**American Electric Power**

**CIGRE GOTF**  
**October 31, 2016**




# Breakthrough Overhead Line Design **BOLD™**

- **A new standard for compact overhead line designs**
  - Achieves greater capacity and efficiency at native voltages
  - Eliminates need for series compensation and other specialized equipment
  - Increases utilization of ROW
  - Reduces environmental and visual impacts
- **Extensive testing and optimization to ensure quality in both design and electrical performance**
- **BOLD to be constructed in two projects in Indiana by AEP**




# **BOLD™ - Concept & Benefits**

- **Theory**
- **Benefits**
- **Development & Testing**




# How BOLD Works



- Key design features:
  - Reduce phase separation into a compact “delta” configuration
  - Optimized bundle diameter
- Reduces line reactance ( $X$ ) and increases charging ( $B$ ), resulting in lower surge impedance ( $\sqrt{X/B}$ ) which boosts surge impedance loading
- Higher degree of intrinsic “self-compensation”
- Arched cross arm and inter-phase insulators designed to hold conductors in exact locations


# BOLD vs. Conventional




<b>Span Length:</b>	<b>850 feet</b>	
<b>Phase Configuration:</b>	<b>3-954 kCM ACSR Cardinal</b>	<b>2-954 kCM ACSR Cardinal</b>
<b>Overall Structure Height:</b>	<b>99'-0" (-31%)</b>	<b>143'-0"</b>
<b>Groundline Moment:</b>	<b>4,700 ft-kips (+2.2%)</b>	<b>4,600 ft-kips</b>
<b>Structure Weights:</b>	<b>43,000 lbs. (+2.4%)</b>	<b>42,000 lbs.</b>

# Power Delivery vs. Profile

## Line Loadability (MW @ 100 miles)



# Noise & EMF Consideration



- *Design allows for installation in constrained right-of-way*
- *Audible noise 3db lower than conventional*
- *Magnetic field 50% lower at same loading level*

# Full-Scale Testing

---

## Electrical Testing

- Corona Inception
- Audible Noise
- Air Gap Electrical Strength
  - Switching Over-Voltage
  - Lightning Over-Voltage

## Structure Testing

- Validate Design Assumptions
- Validate Selection of Material Properties
- Validate Arm Post-Bending Strength





# **BOLD™ - System and Performance Considerations**

- **Insulation Coordination**
- **Fort Wayne Case Study**
- **Western Indiana Case Study**




# Insulation Coordination (IC)

---

- Appropriate line insulators, tower clearances, hardware, tower grounding, and terminal equipment
- Lightning (IC) assesses overvoltage stresses from shielding failures or lightning strikes to the tower or shield wire system relative to a transmission line's insulation strength
  - Lower height results in fewer lightning flashes
  - Improved backflashover rate due to greater phase-to-ground strike distances
  - Virtually eliminates shielding failure flashovers in flat terrain.
  - Estimated lightning performance of BOLD is as good as or better than that of conventional line designs.
- Switching (IC) assesses overvoltage stresses from various switching events relative to a transmission line's insulation strength
  - Without shunt reactors Ph-G and Ph-Ph flashover probabilities are high. Shunt reactor at the receiving end of the line reduced the flashover probabilities essentially to zero.
  - Pre-insertion resistors in 345 kV CB's of BOLD can help reduce Ph-G and Ph-Ph switching over voltages. For BOLD 230 kV, line-end surge arresters can be used to reduce the risk of switching surge flashovers.
  - System strength has a marginal impact on the switching overvoltage level and hence the switching surge flashover rate.

# Fort Wayne, Indiana Case Study




## Reliability Concerns:

- Reactive power deficiency
- Widespread low-voltage conditions
- Multiple 138 kV line overloads

## Contributing Factors:

- Limited local generation
- Fossil unit retirements
- New generation primarily wind
- Heavy power flows into Michigan



# Sorenson Substation Solution



# Line Alternatives Considered

---

- **Rebuild/Reconductor Existing 138 kV Lines**
  - **Pros:** Avoids issues associated with use of higher voltage; low ROW costs
  - **Cons:** Cost to rebuild of nine total lines; requires additional reactive compensation to meet system needs; significant construction outage requirements; age/condition of existing towers questionable for reconductor
- **New Greenfield Conventional 345 kV Double-Circuit Line**
  - **Pros:** No construction outages required; full double-circuit capacity; no need to convert existing substations
  - **Cons:** Length of routes and ROW add cost; significant landowner impacts
- **Rebuild Existing 138 kV Corridor with Conventional Double-Circuit 345 kV Line**
  - **Pros:** Less ROW cost
  - **Cons:** Requires conversion of 138 kV substations to 345 kV; landowner impacts due to new structures and ROW expansion
- **Rebuild Existing 138 kV Corridor with BOLD 345 kV/138 kV Hybrid Line**
  - **Pros:** Less ROW cost; fewer anticipated landowner impacts; no substation conversions; voltage support from line capacitance
  - **Cons:** First use of technology; cost premium compared with conventional designs


# Decision Factors

- **Performance** – high capacity, low impedance of BOLD enabled use of single 345 kV line
  - Achieves 5X capacity in same corridor
  - Self-compensating nature of BOLD design boosts system voltages
- **Right-of-way Considerations** – development and encroachments limited corridor expansion and new line route options
- **Community/Public Impacts** – feedback from public open houses positive toward tower design and profile
- **Other Factors Considered:**
  - **Line Losses** – 3-conductor bundle will reduce losses by approximately 33%
  - **Aging Infrastructure** – need to rebuild existing 1940's vintage line would be required in near future




# Western Indiana Study

- Meadow Lake – Reynolds 345 kV line is approved for BOLD rebuild
- Part of a long 345kV double circuit corridor: Sullivan – Reynolds (~120 miles)
  - Meadow Lake Wind Farm (600 MW nameplate and 200 MW in the PJM queue)
  - Fowler Ridge Wind Farm (750 MW nameplate) connected at Dequine 345 kV station
  - Reynolds – Greentown 765 kV line
- PV analysis shows additional benefits of BOLD



# Transfer Analysis





# Questions

---

