




# Impact of High Levels of distributed PV and Load Dynamics on Bulk Power Transient Stability

**Nicholas W. Miller**  
**GE Energy Consulting**  
**Schenectady, NY USA**  
**Nicholas.miller@ge.com**

**Kara Clark**  
**National Renewable Energy Laboratory**  
**Golden, CO USA**

**2016 CIGRE International Colloquium**  
**October 30, 2016**

# Where are we?




COI

Vincent




# WWSIS-3: Light Spring Load Scenarios

## Base Case




## High Mix Case



WECC-Wide Summary <sup>(1)</sup>	Light Spring Base <sup>(2)</sup>	Light Spring High Mix	Light Spring Extreme Sensitivity
Wind (GW)	20.9	27.2	32.6
Utility-Scale PV (GW)	3.9	10.2	13.5
CSP (GW)	0.9	8.4	8.3
Distributed PV (GW)	0	7.0	10.4
Total (GW) =	25.7	52.8	64.8
Penetration <sup>(3)</sup> (%) =	21%	44%	53%



# Composite Load Model Structure



# Load-induced voltage collapse

- 500kV bus fault, in high density load region
- Standard load model shows N problem
- Composite load caused complete system failure
- No load “self-shedding”... important





Figure 1. Load-induced voltage collapse

# Composite Load Model Structure with Distributed Generation




dPV resides with the load...if you want insight into impact on the BPS, you need a good load model!!




# Impact of Distributed PV on Motor Load Stall induced Voltage Collapse

Adding dPV  
makes the fault  
induced  
transient voltage  
collapse worse in  
this case



# Details of Composite Load Model Behavior

- Load bus voltages at different distances from fault location



Nearby load bus never recovers


Distant load bus collapses when whole system fails



# Details of load behavior relative to fault proximity


Nearby Q jumps up

Nearby dPV blocks




# IMPACT OF SOLAR PV RIDE-THRU BEHAVIOR

- dPV assumed to have pessimistic old IEEE 1547 tripping
- Destabilization of entire WECC grid due to DG tripping on voltage dip




# IMPACT OF DISTRIBUTED PV RECOVERY

- Even with transient stability fail; blocking can be a problem
- Reactive power depletion due to DG tripping on voltage dip



# Impact of DG Tripping during severe frequency events

- Frequency response to trip of 3 Palo Verde units
- DG trip vs. no DG trip on low frequency can exacerbate system problems



# Conclusions

- Dynamic behavior of distributed PV generation has the potential to substantially impact the bulk power system
- Distribution is not decoupled from transmission, and will impact bulk power system operation.
- For transient stability, the system appears to tolerate substantial displacement of thermal generation.
- Poor dynamic behavior of loads can create problems
- Failure of embedded photovoltaics (or other distributed generation) to operate through and, especially immediately after, system faults can greatly exacerbate poor load dynamic behavior.



# Conclusions, continued

- In the extreme, such poor behavior can cause system-wide cascading failures.
- Failure of DG to ride-through disturbances can also cause acute shortages of reactive power and voltage stability problems.
- Conversely, as long as the distributed PV does not trip, it is beneficial to stability of the loads.
- Sensitivity of load active power to voltage changes may effect of bulk system frequency response more than load frequency sensitivity.
- Details vary, basic physics doesn't: These conclusions apply broadly to other grids.



# Acknowledgements

---

The National Renewable Energy Laboratory's (NREL's) contribution to this work was supported by the U.S. Department of Energy under Contract No. DE-AC36-08GO28308 with NREL. Funding provided by the Solar Energy Technologies Office

Thanks  
[nicholas.miller@ge.com](mailto:nicholas.miller@ge.com)



