




Impact of High Levels of distributed PV and Load Dynamics on Bulk Power Transient Stability

Nicholas W. Miller
GE Energy Consulting
Schenectady, NY USA
Nicholas.miller@ge.com

Kara Clark
National Renewable Energy Laboratory
Golden, CO USA

2016 CIGRE International Colloquium
October 31, 2016

Where are we?



COI

Vincent




Transmission line (or lines).
White or colored bars "bundle" the lines
they cross or touch into a numbered

The number alongside
is the WECC number for




WWSIS-3: Light Spring Load Scenarios

Base Case



High Mix Case




WECC-Wide Summary ⁽¹⁾	Light Spring Base ⁽²⁾	Light Spring High Mix	Light Spring Extreme Sensitivity
Wind (GW)	20.9	27.2	32.6
Utility-Scale PV (GW)	3.9	10.2	13.5
CSP (GW)	0.9	8.4	8.3
Distributed PV (GW)	0	7.0	10.4
Total (GW) =	25.7	52.8	64.8
Penetration ⁽³⁾ (%) =	21%	44%	53%

dPV (distributed PV) and DG (distributed generation) are used interchangeably in this presentation



Composite Load Model Structure



Load-induced voltage collapse

- 500kV bus fault, in high density load region
- Standard load model shows N problem
- Composite load caused complete system failure
- No load “self-shedding”... important





Figure 1. Load-induced voltage collapse

Composite Load Model Structure with Distributed Generation




dPV resides with the load...if you want insight into impact on the BPS, you need a good load model!!




Impact of Distributed PV on Motor Load Stall induced Voltage Collapse

Adding dPV
makes the fault
induced
transient voltage
collapse worse in
this case



Details of Composite Load Model Behavior

- Load bus voltages at different distances from fault location




Nearby load bus never recovers

Distant load bus collapses when whole system fails

Details of load behavior relative to fault proximity


Nearby Q jumps up

Nearby dPV blocks




IMPACT OF SOLAR PV RIDE-THRU BEHAVIOR

- dPV assumed to have pessimistic old IEEE 1547 tripping
- Destabilization of entire WECC grid due to DG tripping on voltage dip




IMPACT OF DISTRIBUTED PV RECOVERY

- Even without transient stability fail, blocking can be a problem
- DG trips on voltage dip
- Loss of locally generated active power, increases “import” to the area.
- Reactive power stress on Q resources increases dramatically



Impact of DG Tripping during severe frequency events

- Frequency response to trip of 3 Palo Verde units
- DG trip vs. no DG trip on low frequency can exacerbate system problems



Conclusions

- Dynamic behavior of distributed PV generation has the potential to substantially impact the bulk power system
- Distribution is not decoupled from transmission, and will impact bulk power system operation.
- For transient stability, the system appears to tolerate substantial displacement of thermal generation.
- Poor dynamic behavior of loads can create problems
- Failure of embedded photovoltaics (or other distributed generation) to operate through and, especially immediately after, system faults can greatly exacerbate poor load dynamic behavior.



Conclusions, continued

- In the extreme, such poor behavior can cause system-wide cascading failures.
- Failure of DG to ride-through disturbances can also cause acute shortages of reactive power and voltage stability problems.
- Conversely, as long as the distributed PV does not trip, it is beneficial to stability of the loads.
- Sensitivity of load active power to voltage changes may effect of bulk system frequency response more than load frequency sensitivity.
- Details vary, basic physics doesn't: These conclusions apply broadly to other grids.



Acknowledgements

The National Renewable Energy Laboratory's (NREL's) contribution to this work was supported by the U.S. Department of Energy under Contract No. DE-AC36-08GO28308 with NREL. Funding provided by the Solar Energy Technologies Office

Thanks
nicholas.miller@ge.com



