



# **Operational Flexibility of Large Turbine Generators**

**a message to  
our industry from ...**

**Electric Machinery  
Committee Task Force ....**

**Robert Thornton-Jones  
John Yagielski  
Lon Montgomery**

**Brush Electrical Machines  
GE Power  
Siemens Energy**





# **Operational Flexibility of Large Turbine Generators**

**a message to  
our industry from ...**

**Electric Machinery  
Committee Task Force ....**



**“Coordination of Grid Codes and Generator Standards:  
Consequences of Diverse Grid Code Requirements on  
Synchronous Machine Design and Standards”**



# Operational Flexibility of Large Turbine Generators

- IEEE Task Force Members include Generator Owners, Manufacturers, TSOs, Regulators & Consultants, ...
- ... who are to prepare a report recommending improvements and harmonisations to:
  - 1. Generator Standards IEC60034 & IEEE C50.13.
  - 2. Grid Codes

Bob	Cummings	Lon	Montgomery
Bob	Gray	Luis	Rouco
Carsten	Zuehlke	Marc	Zeidman
Changtai	Xu	Markus	Egretzberger
Chavdar	Ivanov	Matthias	Baechle
Edson	Bortoni	Michel	Rioual
Evert	Agneholm	Mike	Sedlak
Geoff	Klempner	Nico	Smit
Hirohide	Murayama	Nils	Nilsson
Izzy	Kersenbaum	Pierre	Ouellette
Jason	Kapelina	Randall	Groves
Jim	Lau	Raul	Rico
Jim	Michalec	Relu	Ilie
Joe	Hurley	Robert	Thornton-Jones
John	Yagielski	Ruediger	Kutzner
Kay	Chen	Ryan	Quint
Kenichi	Hattori	Satoshi	Mizukami
Kevin	Chan	Steve	Richards
Kevin	Mayor	Thong	Vu Van
Leo	Lima	Uwe	Seeger
Les	Hajagos	William	Bloethe

# Operational Flexibility of Large Turbine Generators

## CONCLUSION:

Cigré, IEC & IEEE must cooperatively pursue describing required attributes of desired operational flexibility ... to include:

- duty cycles (start-stops, MW-MVAR load cycles)
- weighted average efficiency

# Operational Flexibility of Large Turbine Generators

## Operational Flexibility Attributes being discussed:

- Voltage-frequency operating ranges and durations
- Reactive power capability
- Generator short-circuit ratio (SCR)
- Rate of Change of Frequency (RoCoF) withstand capability
- Fault ride through
- Excitation voltage ceiling factor
- Auto-reclosing
- Power output as function of frequency



# Operational Flexibility of Large Turbine Generators

## Operational Flexibility Attributes being discussed:

- Voltage-frequency operating ranges and durations
- Reactive power capability
- Generator short-circuit ratio (SCR)
- Rate of Change of Frequency (RoCoF) withstand capability
- Fault ride through
- Excitation voltage ceiling factor
- Auto-reclosing
- Power output as function of frequency

**See presentations by Luis Rouco & John Yagielski**

# Operational Flexibility of Large Turbine Generators

## Operational Flexibility Attributes being discussed:

- Voltage-frequency operating ranges and durations
- Reactive power capability
- Generator short-circuit ratio (SCR)
- Rate of Change of Frequency (RoCoF) withstand capability
- Fault ride through
- Excitation voltage ceiling factor
- Auto-reclosing
- Power output as function of frequency
- **duty cycles**
- **weighted average efficiency**

A large, hand-drawn style red arrow pointing from the top right towards the bottom left, specifically highlighting the last two items in the list: 'duty cycles' and 'weighted average efficiency'. The text 'Added Topics' is written in red, bold, sans-serif font along the length of the arrow.

**Added Topics**



# Operational Flexibility of Large Turbine Generators


Operational Flexibility Attributes being discussed:

➤ **duty cycles**







# Operational Flexibility of Large Turbine Generators



# Operational Flexibility of Large Turbine Generators

## Changing speed & MW-MVAR in typical daily grid demand profile



- Several start-stops / day & week depending on renewable energy production
- Fast & frequent steps in MW to balance weather dependent renewable energy
- Continuous MVAR variation to stabilize fluctuating grid conditions

provided by  
Siemens  
Energy, Inc.

# Operational Flexibility of Large Turbine Generators

**Excerpt about **duty cycles** from IEC 60034-1 ...**

## **4.1 Declaration of duty**

**It is the responsibility of the purchaser to declare the duty. The purchaser may describe the duty by one of the following:**


- a) numerically, where the load does not vary or where it varies in a known manner**
- b) as a time sequence graph of the variable quantities**
- c) by selecting one of the duty types S1 to S10 that is no less onerous than the expected duty.**

# Operational Flexibility of Large Turbine Generators

**Excerpt about duty cycles from IEC 60034-1 ...**

**c) by selecting one of the duty types S1 to S10 that is no less onerous than the expected duty .....**


**S1 - Continuous running duty**



**S2 - Short-time duty**



**S3 - Intermittent periodic duty**






# Operational Flexibility of Large Turbine Generators

**Excerpt about duty cycles from IEC 60034-1 ...**




**Where the purchaser does not declare a duty, the manufacturer shall assume that duty type S1 (continuous running duty) applies.**



# Operational Flexibility of Large Turbine Generators


**Excerpt about duty cycles from IEC 60034-1 ...**

**b) as a time sequence graph of the variable quantities  
..... perhaps something like this ....**



# Operational Flexibility of Large Turbine Generators

## Changing speed & MW-MVAR in typical daily grid demand profile



- Several start-stops / day & week depending on renewable energy production
- Fast & frequent steps in MW to balance weather dependent renewable energy
- Continuous MVAR variation to stabilize fluctuating grid conditions

provided by  
Siemens  
Energy, Inc.



# Operational Flexibility of Large Turbine Generators


Operational Flexibility Attributes being discussed:

➤ **weighted average efficiency**



# Operational Flexibility of Large Turbine Generators

One specific generator



provided by  
Siemens  
Energy, Inc.

- High number of start-stop cycles
- Operation in whole released capability range (& infrequently at rated load)
- High share of reactive power for grid stabilization
- Full use of under-excitation capability because of capacitive grid demands


**Increased demand on highly flexible  
load operation of conventional power plants**

# Operational Flexibility of Large Turbine Generators

Possibility for flexible operation to increase efficiency:

- Variable operation with fixed H<sub>2</sub> over-pressure
- Variable operation with varied H<sub>2</sub> over-pressure


lower part load losses with varied H<sub>2</sub> overpressure



provided by  
Siemens  
Energy, Inc.

# Operational Flexibility of Large Turbine Generators

## Weighted average efficiency with fixed H2 overpressure




provided by  
Siemens  
Energy, Inc.

**= 99.08% weighted average efficiency**



# Operational Flexibility of Large Turbine Generators

## Weighted average efficiency with fixed H2 overpressure




provided by  
Siemens  
Energy, Inc.

**= 99.08% weighted average efficiency**



# Operational Flexibility of Large Turbine Generators

## Weighted average efficiency with varied H2 overpressure



provided by  
Siemens  
Energy, Inc.


**= 99.17% weighted average efficiency**



# Operational Flexibility of Large Turbine Generators

**Consider: Amend turbogenerator standards to allow specification of several operating points at which efficiency is to be quoted, with % weightings for each point by agreement**

provided by  
Siemens  
Energy, Inc.



fixed H2 pressure @ 75 psig:  
99.06% weighted average efficiency

varied H2 pressure @ 75 - 5 psig:  
99.17% weighted average efficiency





# Operational Flexibility of Large Turbine Generators



**Consider: Amend turbogenerator standards to allow specification of several operating points at which efficiency is to be quoted, with % weightings for each point by agreement**

provided by  
Siemens  
Energy, Inc.

example:

**specify % weights  
for 8 points**

			5
			10
5	20	31	22
			5
			2



fixed H2 pressure @ 75 psig:  
99.06% weighted average efficiency

varied H2 pressure @ 75 - 5 psig:  
99.17% weighted average efficiency

**≈ 800 kW green difference**

# Operational Flexibility of Large Turbine Generators

## CONCLUSION:

Cigré, IEC & IEEE must cooperatively pursue describing required attributes of desired operational flexibility ... to include:

- duty cycles (start-stops, MW-MVAR load cycles)
- weighted average efficiency