



21, rue d'Artois, F-75008 PARIS

<http://www.cigre.org>

## CIGRE US National Committee 2021 Grid of the Future Symposium

### **Unlocking the Queue with Grid-Enhancing Technologies: Case Study of the Southwest Power Pool**

<b>B. TSUCHIDA</b>	<b>J. CASPARY, J. SCHNEIDER</b>	<b>T. BLOCH- RUBIN</b>	<b>J. MARMILLO</b>	<b>P. RUIZ</b>
<b>The Brattle Group USA</b>	<b>Grid Strategies USA</b>	<b>Smart Wires USA</b>	<b>LineVision USA</b>	<b>NewGrid USA</b>

#### **SUMMARY**

Transmission availability has proven to be a major limiting factor in large-scale renewable resource development. As more renewable resources interconnect to the grid without enough transmission capacity to accommodate them, transmission congestion often causes renewable curtailment. While transmission expansion can help alleviate congestion and curtailment issues, major transmission expansion can take years, or even decades, to complete. Renewable capacity, on the other hand, can be developed more quickly, which can leave renewable projects stuck in generator interconnection queues when there is insufficient transmission. If no solution is adopted, the number of renewable projects caught in these queues will increase as intensifying clean energy and carbon reduction goals encourage more renewable development.

Grid-Enhancing Technologies (GETs) allow for quick and cost-effective maximization of the existing transmission system capability by increasing the capacity, efficiency, and reliability of transmission facilities. This study focuses on the combined potential impact of utilizing three technologies on the Southwest Power Pool (SPP) grid: Dynamic Line Ratings (DLR), Advanced Power Flow Control, and Topology Optimization. Using 24 historical power flow snapshots of SPP operations that cover the entire SPP network, the analysis looks at how much additional renewables can be added in Kansas and Oklahoma by the potential transmission capacity improvements from the combined use of all three GETs. After modifying power flow snapshots to reflect projects in interconnection queues, planned generation retirements, and planned transmission expansion, this study estimates that combined GETs usage can double the annual renewable development in Kansas and Oklahoma in 2025 relative to a Base Case with no GETs deployment (2,580 Megawatts [MW] under the Base Case and 5,250 MW with the Change Case, an increase of 2,670 MW, which is more than a 100% increase from the Base Case). GETs installation and annual O&M costs to achieve this are estimated to total \$90 million and \$10 million, respectively. Therefore, the incremental cost of integrating these additional renewables is about \$34/kW, which is about 2 to 3 percent of the assumed development cost of \$1,500/kW for large-scale wind projects. The annual production cost savings from the 2,670 MW of large-scale renewables are estimated to total \$175 million. Additionally, GETs deployment creates over 11,300 direct short-term renewable construction jobs and over 650 direct long-term jobs for operation and maintenance of the renewable resources. Local benefits are also estimated to include over \$32 million in annual tax revenues and \$15 million in land lease revenues. Lastly, GETs deployment generates carbon emissions reductions estimated to total over 3 million tons per year.

Jcaspar@gridstrategiesllc.com

Extrapolating the results of this study in SPP's territory to the national level demonstrates that GETs can enable annual production cost savings increase to over \$5 billion. The corresponding GETs installation and annual O&M costs are \$2.7 billion and \$300 million, respectively. GETs deployment at the national level also creates over 330,000 short-term jobs and nearly 20,000 long-term jobs while local benefits include approximately \$1.5 billion in local taxes and land lease revenues. Additionally, carbon emissions reductions are estimated to increase to nearly 90 million tons annually, which is more than enough to offset all new cars sold in the US on an annual basis.

## **KEYWORDS**

Grid-Enhancing Technologies (GETs), Advanced Power Flow Control, Dynamic Line Ratings (DLR), Topology Optimization, Southwest Power Pool (SPP), Renewable Integration, Transmission Capacity, Flexible Alternating Current Transmission Systems (FACTS)

## **I. Introduction and Scope**

This study assesses how much additional renewable capacity could be integrated onto the SPP grid in the year 2025 with the assistance of DLR, Topology Optimization, and Advanced Power Flow Control technologies (in this specific order), and quantifies the economic and carbon emissions reduction benefits associated with their deployment leading to higher levels of renewable integration. The analysis focuses on deployment specifically in Kansas and Oklahoma as an illustrative case study because they are areas within SPP that have been identified to have significant transmission constraints and planned large-scale renewable capacity. At the time of this analysis, the SPP interconnection queue showed more than 9 Gigawatts (GW) of large-scale renewable resources with executed Interconnection Agreements [1]. Despite the large amount of renewable capacity in the queue, the SPP Integrated Transmission Planning (ITP) reports show high congestion in the region, which would result in renewable generation curtailments once the projects are ultimately placed in service [2].

Traditional thinking treats transmission as if it has a fixed capacity and cannot be operated dynamically. However, much like how advancements in maps and GPS technologies have allowed for safer, easier, and more efficient travel on roads, GETs have allowed for more flexibility in how the grid can be operated. GETs have matured over the past several decades and are commercially proven to be cost-effective and fast-acting solutions on grids around the world. The three GETs considered for this analysis are explained in more detail below.

### **DLR**

Transmission line ratings are traditionally based on Static Line Ratings (SLR) where the maximum operating temperature for a given line is pre-determined. SLR uses conservative assumptions, such as low wind, high temperature, and high solar irradiance, to accommodate most conditions. In a way, it is similar to setting the highway speed limit based on snowy road conditions. Recently, more transmission operators have adopted ambient adjusted rating (AAR).

DLR goes beyond AAR and increases line capacity by adjusting thermal ratings based on actual weather conditions including, at a minimum, ambient temperature and wind, in conjunction with real-time monitoring of resulting line behavior. Other measurements that can be taken into consideration when calculating DLR include line temperature and line sagging. The DOE/ONCOR study indicates DLR transfer capability to be 5% to 25% higher than SLR [3]. DLR is particularly useful in integrating wind energy, as there is a high degree of overlap between wind production and DLR-induced allowable flow increases. European studies indicate DLR contributes to an approximately 15% reduction in wind curtailments in some areas. DLR can also be useful in the accumulation of real-time data, which can be used for future calibration, as DLR is variable and requires a forecast for operations planning.

### **Topology Optimization**

Topology Optimization automatically finds reconfigurations to re-route flow around congested or overloaded facilities while meeting reliability criteria. Power flow re-routing is achieved by switching circuit breakers open or close, which has a similar effect to power flow control technologies (discussed next) while using existing equipment. In a sense, Topology Optimization is analogous to temporarily diverting traffic away from congested roads to make traffic smoother and is often referred to as the “Waze” for the transmission grid.

Reconfiguring the grid in operations is feasible today. Circuit breakers are capable of high duty cycles and are extremely reliable. Some breakers are switched very frequently today – for example, those connecting generating units have daily start and stop operations. Additionally, switching infrastructure is already in place—most breakers are controlled remotely over Supervisory Control and Data

Acquisition (SCADA) by the transmission operator. Topology Optimization is relatively low cost and usually costs approximately \$10-\$100 per switching cycle.

## **Advanced Power Flow Control**

Power flow control technologies can come in the form of Phase Shifting Transformers (PSTs), also referred to as Phase Angle Regulators (PARs). These technologies have been widely accepted in the industry. The largest drawback for these technologies is the deployment cost—for example, a recently-installed PAR between Michigan and Ontario has an annual carrying cost of over \$10 million. Flexible Alternating Current Transmission Systems (FACTS) are power-electronic-based static devices that allow for flexible and dynamic control of flow on transmission lines or the voltage of the system. Advanced Power Flow Control analyzed in this study is a FACTS device that alters the reactance of a line to control the flow (i.e., increasing the reactance will push away flows while decreasing the reactance will pull in more flow to the line). FACTS devices typically cost less than PARs, can be manufactured and installed in a shorter time frame, are scalable, and in many cases are available in mobile form that can be easily deployed (or redeployed, as needed) while providing flexible layout options. Today's Advanced Power Flow Control technology deployments are typically cost competitive with legacy power flow control, and a fraction of the cost of new line construction or rebuilds.

The rest of the study is structured as follows. Section II contains the analysis approach, section III contains the study results, and section IV concludes.

## **II. Analysis, Approach, and Assumptions**

The analysis approach for this report is composed of the following five steps:

### **Step 1: Identify preferred area for analysis**

GETs focus on transmission operations and planning and are particularly helpful in increasing renewable penetration when transmission congestion curtails renewables (or prevents their interconnection). More renewables (largely wind in SPP) will also likely lead to higher levels of transmission congestion if there is no significant transmission expansion. Therefore, the preferred areas identified in this study are (1) areas with transmission constraints identified in SPP transmission studies, and (2) areas with significant generation resource changes (large amounts of new renewable projects and retirements of existing resources). Based on the observations from SPP's 2019 Integrated Transmission Planning (ITP) report and Generator Interconnection (GI) queue, Kansas and Oklahoma are selected as focus areas. The ITP report identifies two target areas:

- **Southeast Kansas/Southwest Missouri Target Area (Target Area 1):** Southeast Kansas/Southwest Missouri was identified as Target Area 1, requiring additional analysis for several reasons. The area has been the site of historic and projected congestion on the EHV system and has had unresolved transmission limits identified in multiple studies, most recently in the 2018 ITPNT. By defining this corridor as a target area in the 2019 ITP, SPP can address the TWG's direction to provide a path forward for the area to properly evaluate and resolve the issues present in day-to-day operations and in the planning horizon.
- **Central/Eastern Oklahoma Target Area (Target Area 2):** Central/Eastern Oklahoma was identified as Target Area 2 due to heavy congestion and parallel system correlation with Target Area 1. Additional analysis was unnecessary for Target Area 2 because system issues in this area were only related to congestion and underlying voltage stability concerns. The main point of congestion in Target Area 2 is related to the Cleveland 345/138 kV station west of Tulsa, Oklahoma. The renewable forecast in the 2019 ITP drives increased bulk transfers

across central Oklahoma. EHV contingencies in the area shift congestion mostly to the lower-voltage system.

For Kansas and Oklahoma in particular, SPP’s GI Queue shows significant renewable additions and material retirements of existing generation resources as shown in table 1 below:

**Table 1: Planned Capacity and Retirement 2020-2025**

Control Area	Entity	Planned Capacity (MW)				Planned Retirement (MW)			
		Total	Solar	Wind	Battery	Total	Fuel Oil	Coal	Natural Gas
KS/OK	OKGE Oklahoma Gas & Electric Co	10,837	2,036	7,623	1,178	339	28		312
	Energy Energy	10,276	1,812	8,148	316	1,223	410		813
	KCPL Kansas City Power & Light	2,911	550	2,361	-	727	297		431
	WERE Westar Energy	7,365	1,262	5,787	316	893	114		382
	SPS Southwestern Public Service Co	13,122	6,985	5,088	1,049	920			920
	AEPW American Electric Power West	9,335	3,249	5,344	742	474	12	-	462
	BEPC Basin Electric Power Coop	2,740	700	2,040	-				
	LES Lincoln Electric System	1,065	306	659	100	99			99
	MIDW Midwest	948	50	878	20				
	NPPD Nebraska Public Power District	6,806	2,025	4,707	74	354	178		176
OPPD Omaha Public Power District	1,808	1,027	135	646	605	136	199	270	
SUNC Sunflower Electric Power Corp	4,163	1,110	3,003	50	431	84		346	
WAPA WAPA Upper Great Plains West	3,441	388	3,053	-					
WFEC Western Farmers Electric Coop	2,265	1,404	677	184	130			130	
AR Other AR Utilities	126	126	-	-	5	5			
IA Other IA Utilities	300	-	300	-	6	6			
KS Other KS Utilities	7,465	5,041	1,729	695	166	66		100	
LA Other LA Utilities	440	330	-	110					
MN Other MN Utilities	-	-	-	-	43	43			
MO Other MO Utilities	5,176	3,031	1,642	503	427	74	165	188	
MT Other MT Utilities	510	75	385	50					
ND Other ND Utilities	1,033	72	887	74	4	4			
NE Other NE Utilities	3,497	2,026	1,171	300					
NM Other NM Utilities	500	500	-	-					
OK Other OK Utilities	3,396	2,001	1,143	252	540			540	
SD Other SD Utilities	1,832	63	1,705	63	34	10		24	
TX Other TX Utilities	2,482	920	852	710					
<b>Total</b>		<b>94,920</b>	<b>36,092</b>	<b>51,712</b>	<b>7,116</b>	<b>6,197</b>	<b>1,097</b>	<b>904</b>	<b>4,197</b>

Selection criteria for new renewables projects are set to those where Interconnection Agreements have been fully executed. This approach includes over 9,400 MW of renewable projects, as shown in table 2 below:

**Table 2: Renewable Potential Assumed for Kansas and Oklahoma**

State	Wind	Solar	Total
Kansas	3,410	120	3,530
Oklahoma	5,760	140	5,900
<b>Total</b>	<b>9,170</b>	<b>260</b>	<b>9,430</b>

Note: Rounded to the nearest 10 MW


**Step 2: Select 24 representative snapshots from SPP operational power flow cases**

The study analyzed 24 snapshots representing varying conditions over a full year for the entire SPP territory. This is an alternative approach to performing production simulation type analyses and will likely reflect historical operational conditions better than production simulations. This section discusses how the 24 snapshots were selected.

All hours from a calendar year (summer 2019 through summer 2020) were sorted by decreasing net load (i.e., SPP load minus SPP wind) and divided into 25 bins (numbered 1 through 25), with each bin containing about 1/25th of the total annual curtailment observed. These bins are shown in figure 1 below, where the areas between the red lines mark each of the 25 bins. The count of hours is higher in bins where the net load (shown as the thick black line in the chart) is higher (i.e., towards the left side

of the figure). The curtailment rate (curtailment per hour, shown in %) increases towards the right-hand side of the chart (as the distance between the red lines, or count of hours represented in each bin, decrease).

**Figure 1: Net Load and Wind Curtailment**



A more granular look into the bin information can be found in table 3 below. When analyzing the bins below, the first bin (bin 25) is excluded, as it represents the minimal average curtailment rates (fourth column in table):

**Table 3: Bin Information**

<b>BIN INFORMATION</b>					
<b>Bin</b>	<b>Wind Production Potential [MWh]</b>	<b>Wind Curtailment [MWh]</b>	<b>Average Curtailment [%]</b>	<b>Average Curtailment [MWh]</b>	<b>No of Hours</b>
1	930,179	56,420	6%	973	58
2	801,517	57,229	7%	1,122	51
3	995,079	55,534	6%	868	64
4	1,190,204	56,178	5%	711	79
5	1,272,130	56,782	4%	668	85
6	1,418,124	56,184	4%	579	97
7	1,454,767	56,198	4%	573	98
8	1,690,406	57,186	3%	485	118
9	1,734,496	55,497	3%	455	122
10	1,916,544	56,104	3%	422	133
11	1,743,862	56,538	3%	449	126
12	2,054,919	55,794	3%	374	149
13	2,111,623	56,131	3%	364	154
14	2,154,600	56,823	3%	351	162
15	2,569,128	56,044	2%	289	194
16	2,698,718	56,007	2%	269	208
17	3,225,928	56,365	2%	217	260
18	2,680,982	56,487	2%	262	216
19	3,792,959	56,089	1%	179	313
20	4,647,197	56,480	1%	130	434
21	4,940,542	56,082	1%	117	480
22	5,436,156	56,237	1%	98	575
23	6,560,518	56,340	1%	75	750
24	10,239,766	56,239	1%	39	1436
25	13,951,550	56,266	0%	23	2421

Historical power flow cases that best represent bins 1 through 24 in the figure above (i.e., snapshots) are then selected. The 24 snapshots span the conditions where wind curtailment occurs as shown in table 4 below. To maintain a daily and seasonal spread, we avoid choosing hours from the same day:


**Table 4: Bin Information – Representative Hour Selections**

<b>Bin</b>	<b>Date</b>	<b>Time</b>
1	April 12, 2020	Early Morning
2	September 28, 2020	Early Morning
3	June 1, 2020	Early Morning
4	September 21, 2020	Early Morning
5	June 13, 2020	Early Morning
6	September 9, 2020	Early Morning
7	March 8, 2020	Mid Day
8	January 9, 2020	Early Morning
9	November 11, 2019	Late Afternoon
10	January 8, 2020	Late Afternoon
11	April 18, 2020	Early Morning
12	September 10, 2020	Early Morning


13	December 7, 2019	Late Afternoon
14	April 16, 2020	Late Afternoon
15	March 4, 2020	Late Night
16	December 19, 2019	Late Afternoon
17	May 10, 2020	Late Night
18	November 15, 2019	Late Afternoon
19	December 11, 2019	Late Afternoon
20	November 16, 2019	Mid Day
21	August 13, 2020	Early Morning
22	September 6, 2020	Mid Day
23	August 20, 2020	Late Night
24	June 26, 2020	Late Night

Wind production potential and curtailment for each bin can be found in figures 2 and 3 below. The wind production potential in the sample ranges from 7.9 to 18.3 GWs, with the average value totaling 14.3 GW.

**Figure 2: Wind Production Potential in Selected Snapshots**



**Figure 3: Curtailment in Selected Snapshots**



**Step 3: Modify the snapshots**

Each of the 24 snapshots is then modified to model 2025 by reflecting new transmission upgrades, wind/solar units and announced retirements from the SPP GI queue, and load changes. To account for transmission changes, we adjust transmission constraint limits by comparing binding constraints against historical data (and adjust as necessary). Additionally, we added over 70 transmission projects from SPP’s ITP reports that are planned to be in service by 2025, as summarized in table 5 with details in tables 6-9:

**Table 5: Summary of Transmission Projects**

Voltage Level	Project Counts
230 KV and Above	16
169 kV and 138 kV	27
115 kV	16
69 kV	14
<b>Total</b>	<b>73</b>

**Table 6: Planned Transmission Projects from 2019 ITP for 2020-2025 (230 kV and Higher)**

Project Name	Project Type	Owner	Project Status	In-Service Date
Multi - Gentleman - Cherry Co. - Holt Co. 345 kV	Regional Reliability	NPPD	Delay - Mitigation	6/1/2022
XFR - Thedford 345/115 kV	High Priority	NPPD	Delay - Mitigation	5/1/2021
XFR - Wolfforth 230/115 kV Ckt 1 Transformer	Regional Reliability	SPS	On Schedule < 4	4/15/2021
Sub - Amarillo South 230 kV Terminal Upgrades	Regional Reliability	SPS	On Schedule < 4	4/1/2020
XFR - Sundown 230/115 kV Transformer	Regional Reliability	SPS	Delay - Mitigation	12/15/2020
Multi - Tuco - Yoakum 345/230 kV Ckt 1	Regional Reliability	SPS	Delay - Mitigation	6/1/2020
Sub - Nichols - 230 kV	Regional Reliability	SPS	Delay - Mitigation	5/15/2020
Multi - Sheldon - Monolith 115 kV	Regional Reliability	NPPD	Delay - Mitigation	1/1/2021
XFR - Lawrence Hill 230/115kV	Regional Reliability	WR	Delay - Mitigation	6/1/2021
XFR - McDowell 230/115 kV Ckt 1	Regional Reliability	SPS	Delay - Mitigation	5/28/2021
Multi - China Draw - Road Runner 345 kV	Regional Reliability	SPS	Delay - Mitigation	11/15/2021
Line - Eddy County - Kiowa 345 kV New Line	Regional Reliability	SPS	On Schedule < 4	11/15/2020
Multi - S1361	Regional Reliability	OPPD	On Schedule < 4	6/1/2021
Multi - Cimarron - Northwest - Mathewson 345kV	Economic	OGE	On Schedule < 4	7/1/2020
Multi - Neset - New Town 230 kV	Regional Reliability	BEPC	Re-evaluation	12/31/2022
Sub - Neosho 345 kV	Sponsored Upgrade	WR	On Schedule < 4	7/1/2020

**Table 7: Planned Transmission Projects from 2019 ITP for 2020-2025 (138 kV and 169 kV)**

Project Name	Project Type	Owner	Project Status	In-Service Date
Line - Cedar Grove - South Shreveport 138 kV	Transmission Service	AEP	On Schedule < 4	6/1/2020
Line - Keystone Dam - Wekiwa 138 kV Ckt 1 Rebuild	Regional Reliability	AEP	On Schedule < 4	6/1/2021
Line - Lincoln - Meeker 138 kV Ckt 1 New Line	Regional Reliability	OGE	Delay - Mitigation	7/31/2020
Multi - Driftwood 138/69 kV Substation and Transformer	Regional Reliability	WFEC	Delay - Mitigation	4/1/2022
Multi - DeGrasse - Knob Hill 138 kV New Line and DeGrasse 345/138 kV	Regional Reliability	WFEC	Delay - Mitigation	12/1/2024
Sub - Cleo Junction 138 kV Terminal Upgrades	Regional Reliability	WFEC	Delay - Mitigation	5/31/2023
Line - Crosstown - Blue Valley 161 kV New Line	Regional Reliability	KCPL	Re-evaluation	6/30/2023
Sub - Tupelo - Tupelo Tap 138 kV Terminal Upgrades	Economic	WFEC	Delay - Mitigation	12/31/2020
XFR - Creswell 138/69/13.2 kV Transformers	Regional Reliability	WR	On Schedule < 4	6/1/2021
Multi - Park Community - Sunshine 138 kV	Regional Reliability	WFEC	Delay - Mitigation	5/31/2021
Line - Cogar - OU SW 138 kV	Regional Reliability	WFEC	Delay - Mitigation	3/1/2024
Sub - Westmoore 138 kV	Regional Reliability	OGE	On Schedule < 4	12/31/2020
Sub - Santa Fe 138 kV	Regional Reliability	OGE	Re-evaluation	6/1/2021
Sub - Riverside Station 138 kV	Regional Reliability	AEP	Delay - Mitigation	11/1/2022
Sub - Southwestern Station 138 kV	Regional Reliability	AEP	Delay - Mitigation	11/1/2022
Sub - Moore 13.8 kV Breaker	Regional Reliability	NPPD	On Schedule < 4	6/1/2021
Sub - Craig 161 kV	Regional Reliability	KCPL	On Schedule < 4	12/31/2021
Sub - Leeds 161 kV	Regional Reliability	KCPL	On Schedule < 4	12/31/2020
Sub - Southtown 161 kV	Regional Reliability	KCPL	On Schedule < 4	12/31/2021
Sub - Mooreland 138/69 kV Breakers	Regional Reliability	WFEC	On Schedule < 4	5/1/2022
Line - Tulsa SE - S Hudson 138kV Ckt 1	Regional Reliability	AEP	Delay - Mitigation	11/1/2021
Line - Tulsa SE - 21st Street Tap 138kV Ckt 1	Regional Reliability	AEP	Delay - Mitigation	11/1/2021
Line - East Kingfisher - Kingfisher 138kV	Economic	WFEC	On Schedule < 4	1/1/2021
Line - Neosho - Riverton 161 kV	Transmission Service	EDE	NTC-C Project Estimate	10/1/2023
XFR - Pryor Junction 138/115	Regional Reliability	AEP	Delay - Mitigation	11/30/2021
Line - Anadarko - Gracemont 138kV	Economic	WFEC	On Schedule < 4	1/1/2021
Jayhawk Wind 161/69kV Transformer	Sponsored Upgrade	Apex		12/31/2021

**Table 8: Planned Transmission Projects from 2019 ITP for 2020-2025 (115 kV)**

Project Name	Project Type	Owner	Project Status	In-Service Date
Line - Northwest - Rolling Hills 115 kV Ckt 1	Regional Reliability	SPS	On Schedule < 4	5/15/2021
Line - Ainsworth - Ainsworth Wind 115 kV Ckt 1 Rebuild	Regional Reliability	NPPD	On Schedule < 4	6/1/2020
Sub - Carlsbad - Pecos 115 kV Terminal Upgrades	Regional Reliability	SPS	On Schedule < 4	6/1/2021
Carlisle - Murphy 115kV Terminal Upgrades	Regional Reliability	SPS	On Schedule < 4	6/1/2022
Sub - Carlsbad Interchange 115 kV	Regional Reliability	SPS	On Schedule < 4	6/1/2021
Sub - Hale Cty Interchange 115 kV	Regional Reliability	SPS	On Schedule < 4	6/1/2021
Sub - Denver City Interchange 115 kV North	Regional Reliability	SPS	On Schedule < 4	6/1/2021
Sub - Canaday 115 kV	Regional Reliability	NPPD	On Schedule < 4	6/1/2021
Sub - Hastings 115 kV	Regional Reliability	NPPD	On Schedule < 4	6/1/2021
Multi - Marshall County - Smittyville - Baileyville - South Seneca 115 kV	Regional Reliability	WR	Delay - Mitigation	6/1/2023
Sub - Firth 115kV	Regional Reliability	NPPD	Delay - Mitigation	6/1/2023
Sub - Amoco - Sundown 115 kV	Economic	SPS	On Schedule < 4	6/1/2020
Line - Hansford - Spearman 115kV	Economic	SPS	On Schedule < 4	1/1/2021
Multi-Hobbs Interchange-Millen 115kV	Regional Reliability	SPS	On Schedule < 4	6/1/2022
Sub - Denver City Interchange South 115 kV	Regional Reliability	SPS	On Schedule < 4	6/1/2021
Line - Aberdeen City - Aberdeen Industrial Park 115 kV	Sponsored Upgrade	NWE	On Schedule < 4	12/31/2021

**Table 9: Planned Transmission Projects from 2019 ITP for 2020-2025 (69 kV and Lower)**

Project Name	Project Type	Owner	Project Status	In-Service Date
Line - Elmore - Paoli 69 kV Rebuild	Regional Reliability	WFEC	Delay - Mitigation	3/1/2022
Line - Sara Road - Sunshine Canyon 69 kV Ckt 1 Rebuild	Regional Reliability	WFEC	Delay - Mitigation	12/31/2019
Device - S964 69 kV Cap Bank	Regional Reliability	OPPD	On Schedule < 4	6/1/2020
Line - Atoka - Atoka Pump - Pittsburg - Savanna - Army Ammo - McAlester City	Zonal Reliability	AEP	Delay - Mitigation	11/20/2020
Line - City of Winfield - Oak 69 kV Reconnector	Regional Reliability	KPP	On Schedule < 4	12/30/2020
Device - Dover SW 69 kV Cap Bank	Regional Reliability	WFEC	Delay - Mitigation	9/1/2023
Device - Cherokee SW 69 kV Cap Bank	Regional Reliability	WFEC	Delay - Mitigation	8/1/2023
Device - Clear Creek Tap 69 kV Cap Bank	Regional Reliability	WFEC	Delay - Mitigation	12/1/2020
Sub - Washita 69 kV	Regional Reliability	WFEC	On Schedule < 4	6/1/2021
Device- Gypsum 69 kV Capacitor Bank	Regional Reliability	WFEC	On Schedule < 4	6/1/2021
Sub - Cleo Corner - Cleo Junction 69kV	Regional Reliability	OGE	On Schedule < 4	6/1/2022
SUB - Marietta - Rocky Point 69 kV	Regional Reliability	WFEC	On Schedule < 4	12/1/2021
SUB - Forest Hill 69 kV Terminal Upgrades	Regional Reliability	OGE	On Schedule < 4	1/1/2021
DPNS-2019-March-1011 Shell Rock and Bauman Substation	Regional Reliability	CBPC	NTC - Commitment	6/1/2020

We also identify outages in the snapshots that correspond to capital projects and put them back in service. We additionally setup single-element contingencies in SPP and neighboring areas (Mid-American, Associated Electric, Entergy etc.).

The analysis also reflects changes in generation. To do this we add new wind and solar units from the SPP GI queue and assume added units' max potential output based on capacity factor from nearby units of the same type (this is done by snapshot). We also adjust wind/solar dispatch to reverse curtailment by observing historical data on Locational Marginal Prices (LMPs) to identify units that may have been curtailed (e.g., LMP less than -\$20/MWh). For assumed curtailments, we estimate what the non-curtailed dispatch might have been using nearby wind/solar units. We also track any new thermal generation additions or retirements in the GI queue.

For the purposes of the study, load is adjusted to reflect 2025 levels. SPP estimates 240 MW of load growth between 2020 and 2025. The analysis also removes the portion of Lubbock load (470 MW) that is scheduled to transfer to ERCOT in 2021 [4]. Finally, the study assumes imports and exports with neighboring areas to remain constant at historical levels.

**Step 4: Find the maximum amount of renewables that can be integrated under a business-as-usual scenario (Base Case) vs. a scenario with GETs (With GETs Case)**

The base case is created by dispatching wind and solar to their max output by running Security Constrained Optimal Power Flow (SCOPF). The output of non-renewable units is then adjusted in the following ways:

- If capacity is < 100 MW, allow the unit to shut down.
- If capacity is  $\geq$  100 MW, assume the unit's min-gen is 30% of max-capacity.
- For nighttime snapshots, allow natural gas-fueled combined-cycle units and simple cycle units to shut down as needed.
- Leave nuclear units and units outside of SPP operating as is (i.e., no redispatch).

A priority order is then established for wind and solar (existing wind/solar is prioritized over new wind/solar).

The analysis assesses curtailment without GETs. First, we perform contingency analysis and add appropriate interfaces needed to represent the contingency analysis results. We enforce transfer limits for all lines 69 kV and higher within SPP, and 100 kV and higher for external regions. We then add the new renewable projects (over 9 GW) to the power flow cases and solve SCOPF to identify feasible projects. For new renewable projects (9,430 MW-worth from GI Queue), we assume a 5% curtailment threshold for viability assessment (i.e., projects are considered viable if the analysis indicates annual curtailments to be less than 5%). This is performed through an iterative process (i.e., we first add all 9+ GW of large-scale renewable projects, run SCOPF, identify projects with high curtailments, take out those renewable projects with high curtailments, add back the rest of the projects, then resolve SCOPF, identify projects with high curtailment levels from this subset of projects, take them out, and repeat this process until all projects remaining are deemed feasible with annual curtailments below the threshold level).

The maximum amount of renewables that can be integrated in the Base Case and the With GETs Case are found by solving the power flow cases (for the entire SPP footprint) with and without GETs. When assessing the With GETs Case, the analysis identifies opportunities presented first by DLR, then by Topology Optimization, and lastly by Advanced Power Flow Control. The With GETs Case analysis assumes the same 5% threshold to assess project viability. It is important to note that the results are for the combined benefits of GETs usage, rather than for individual GETs. The order of GETs implemented in the analysis will likely change the benefits reaped by the individual technologies (i.e., being the first technology to be added would likely show larger benefits than being last).

**Step 5: Assess benefits including economic values (production cost savings, job creation, local benefits, etc.) and carbon emissions reduction.**

The analysis outlined in Step 4 will determine the projects that are feasible and provide the total capacity (MW) of such projects. To assess the benefits of deploying GETs on the SPP grid we first calculate the annual generation (MWh) from these feasible projects. In doing so, we rely on historical generation level by renewable type (i.e., solar and wind). For this study we conservatively assumed a 37.5% capacity factor for wind (based on average capacity factor of all existing wind within SPP) and 18.0% for solar. This is conservative because newer plants do show higher capacity factors. We then convert the generation values into production cost benefits and carbon emission benefits utilizing SPP market data where applicable. We further reviewed public studies on the economic impacts to estimate "per unit" benefits and apply those to the findings. In addition, we relied on cost data provided by GETs vendors for both initial investment and the ongoing operational costs once installed.

To estimate the number of renewable jobs generated from the increased amount of renewable energy capacity facilitated by GETs, we reviewed 14 public reports shown in table 10 below to assess job impacts through wind investments. 11 of the 14 reports had useful information, and include information regarding direct, indirect, and induced jobs. The data generally reflects short-term jobs (e.g., construction jobs) rather than long-term O&M jobs, and the impacts are largely at the state level (or smaller geographical areas).


**Table 10: 11 Studies on the Economic Benefits of Wind Development**

Study	Region
Aldieri et. al, Wind Power and Job Creation, 2019	U.S. and other countries
AWEA, Wind Powers America Annual Report, 2019	Nationwide
Brattle, Job and Economic Benefits of Transmission and Wind Generation Investments in the SPP Region, 2010	SPP
EIG, Statewide Economic Impact of Wind Energy Development in Oklahoma, 2014	Oklahoma
NREL, Economic Impacts from Wind Energy in Colorado Case Study, 2019	Rush Creek Wind Farm, Colorado
NREL, Economic Development Impact of 1,000 MW of Wind Energy in Texas, 2011	Texas
NREL, Economic Impacts from Indiana’s First 1,000 MW of Wind Power, 2014	Indiana
NREL, Estimated Economic Impacts of Utility Scale Win Power in Iowa, 2013	Iowa
NREL, Jobs and Economic Development from New Transmission and Generation in Wyoming, 2011	Wyoming
UC Berkeley, Job Impacts of California’s Existing and Proposed RPS, 2015	California
USDA, Ex-Post Analysis of Economic Impacts from Wind Power Development in U.S. Counties, 2012	Great Plains and Rocky Mountains

Note: Three additional studies reviewed (whose data was not directly applicable to the analysis) are: NREL, Analysis of the Renewable Energy Projects Supported by 1603 Treasury Grant Program, 2012; NYSERDA, New York Clean Energy Industry Report, 2019; and NREL, Counting Jobs and Economic Impacts From Distributed Wind in the United States, 2014.

Figure 4 below aggregates the data found in the 11 studies above:

**Figure 4: Comparison of Job Impacts Across Studies**




We also estimate the local benefits generated by increasing renewable production. A review of the 7 public reports in table 11 allows us to compare the land lease and tax revenues from wind development, found in figure 5 below.

**Table 11: 7 Studies on the Economic Benefits of Wind Development**

Study	Region
EIG, Statewide Economic Impact of Wind Energy Development in Oklahoma, 2014	Oklahoma
NREL, Economic Impacts from Wind Energy in Colorado Case Study, 2019	Rush Creek Wind Farm, Colorado
NREL, Economic Development Impact of 1,000 MW of Wind Energy in Texas, 2011	Texas
NREL, Economic Impacts from Indiana’s First 1,000 MW of Wind Power, 2014	Indiana
NREL, Estimated Economic Impacts of Utility Scale Win Power in Iowa, 2013	Iowa
NREL, Jobs and Economic Development from New Transmission and Generation in Wyoming, 2011	Wyoming
Wind Powers America Annual Report, 2019	USA state-level data

Note: The WPA annual report contained data for each state. All other sources report values from a single project.

**Figure 5: Comparison of Lease and Tax Revenues Across Studies and States**



### III. Study Results

#### Renewables Under Base Case

Under the Base Case, approximately 2,580 MWs of renewable capacity can be integrated to the SPP grid in 2025. A few contributing factors include the retirement of existing thermal resources and the load growth from 2020-2025. Additionally, the Lubbock load departure works against the integration of renewables since it requires more renewable exports from the south plains of SPP. Table 12 below shows renewable integration in the Base Case in more detail:

**Table 12: Additional Renewables Integrated – Base Case**

State	Potential (MW)			Base Case (MW)			Realization (%)		
	Wind	Solar	Total	Wind	Solar	Total	Wind	Solar	Total
Kansas	3,410	120	3,530	1,710	0	1,710	50%	0%	48%
Oklahoma	5,760	140	5,900	770	100	870	13%	71%	15%
Total	9,170	260	9,430	2,480	100	2,580	27%	38%	27%

Note: Rounded to the nearest 10 MW

### Renewables Under With GETs Case

The GETs utilized in the With GETs Case include DLR on 56 lines (15 to 30 sensors per DLR installation), 204 unique Topology Optimization reconfigurations, which average 13 per snapshot, and Advanced Power Flow Control at 8 locations. For Topology Optimization, average actions represent the average number of actions that remain per snapshot, not actions per hour. Based on other studies the average number of actions per hour is expected to be smaller, typically less than the number of topology changes due to planned outages. Tables 13 and 14 below outline hardware and software solutions by voltage level:

**Table 13: Hardware Solutions by Voltage Level**

Hardware Solutions by Voltage Level	345	230	161	138	115	69	Total
DLR	10	3	11	22	3	7	56
Advanced Power Flow Control	3	0	4	1	0	0	8

**Table 14: Software Solutions by Voltage Level**

Software Solutions by Voltage Level	345	230	161	138	115	69	Total
Lines	20	10	31	75	4	30	170
Substations	4	0	1	1	0	0	6
Transformers (high voltage terminal)	10	1	4	13	0	0	28

The estimated initial investment costs are around \$90 million, while ongoing costs are estimated to total around \$10 million per year. It is important to note that costs can vary project by project, and also based on how the GETs service is provided. For example, Topology Optimization can be provided as a software subscription service to reduce the initial cost. We also assume utilities can incorporate these technologies into their existing control systems without large costs.

In the study areas of focus, the installation of GETs allows for over 5,200 MW of new renewables to be integrated onto the grid as shown in table 15 below. This is more than twice the amount of renewables integrated in the Base Case:

**Table 15: Additional Renewables Integrated – With GETs Case**

State	Potential (MW)			With GETs Case (MW)			Realization (%)		
	Wind	Solar	Total	Wind	Solar	Total	Wind	Solar	Total
Kansas	3,410	120	3,530	1,910	0	1,910	56%	0%	54%
Oklahoma	5,760	140	5,900	3,200	140	3,340	56%	100%	57%
Total	9,170	260	9,430	5,110	140	5,250	56%	54%	56%

Note: Rounded to the nearest 10 MW

A side-by-side comparison of additional renewables integrated in the Base Case and the With GETs case can be found in table 16 below:

**Table 16: Additional Renewables Integrated Base Case vs. With GETs Case**

State	Base Case			With GETs Case			Delta (GETs - Base)		
	Wind	Solar	Total	Wind	Solar	Total	Wind	Solar	Total
Kansas	1,710	0	1,710	1,910	0	1,910	200	0	200
Oklahoma	770	100	870	3,200	140	3,340	2,430	40	2,470
Total	2,480	100	2,580	5,110	140	5,250	2,630	40	2,670

Note: Rounded to the nearest 10 MW

The difference of 2,670 MW is approximately 1.5 times the amount of wind integrated in SPP in 2019 (1.8 GW). The \$90 million in GETs investment enabling 2,670 MW of additional renewables calculates to approximately \$34/kW for new renewables, or about 2% (less than 2.5%) of a typical new wind project investment cost estimated to be \$1,500/kW.

This 2,670 MW conservatively translates to 8,776 Gigawatt-hours (GWh), of additional renewables integrated as a result of GETs deployment. It is made up of 2,630 MW/8,640 GWh of wind energy per year, and 40 MW/60 GWh of solar energy per year, assuming the aforementioned capacity factors of 37.5% for wind and 18.0% for solar, respectively.

**Benefits of Increased Renewables**

The estimated annual production cost savings from GETs deployment are estimated to total over \$175 million. This production cost savings value is calculated by conservatively assuming \$20/MWh savings for the 8,776 MWhs of new renewables. This assumption is based on an estimated cost of generation from a new natural gas-fueled combined-cycle plant in the \$20/MWh to \$25/MWh range (assuming \$2.5-3.0/ Million Metric British Thermal Units [MMBtu] fuel cost and 7,000 Btu/kWh heat rate plus Variable Operations and Maintenance [VOM]). Additionally, generation costs of coal plants would be in the \$20/MWh to \$25/MWh range (assuming \$2/MMBtu fuel cost and 10,000 Btu/kWh heat rate plus VOM). LMPs can be used as an indicator for the marginal cost of power. The SPP State of the Market Report shows 2019 day-ahead prices averaged around \$22/MWh and real-time prices averaged around \$21/MWh [5]. The 2018 average was \$25/MWh for both new natural gas-fueled combined-cycle plants and coal plants. It is important to note this value does not include any

Production Tax Credit-driven savings. With an estimated \$175 million of production cost savings, the payback for GETs investment (estimated at \$90 million) is about half a year.

Integrating an additional 2,670 MWs of renewables using GETs also yields environmental benefits. This analysis estimates carbon emissions reductions to total over 3 million tons per year. To calculate this value, we conservatively assume the additional new renewables replace carbon emissions from natural gas-fueled combined-cycle plants (with emission estimated to be 350g per kWh, or 0.8 pounds per kWh). In reality, the new renewables may replace less efficient resources with higher emissions. Additional benefits include reduced water usage. By enabling twice the amount of renewables to be integrated, the reduction in water usage for power production is doubled.

Renewables integration also creates jobs and other local benefits. The additional 2,670 MWs (2,430 MW in Oklahoma and 200 MW in Kansas) are estimated to create:

- Over 11,300 direct short-term jobs (largely construction of renewables), assuming 4.3 jobs (person-year) /MW for wind and 1.3 jobs (person-year)/MW for solar.
- Over 650 direct long-term jobs for operation and maintenance of the renewable resources, assuming 0.25 jobs (person-year)/MW for wind and 0.005 jobs (person-year)/MW for solar.
- \$32 million in annual tax revenues and \$15 million in land lease revenues. Tax revenues assume \$13,000/MW for the 2,430 MW in Oklahoma and \$4,700/MW for the 200 MW in Kansas. Land lease revenues assume \$5,900/MW for both Kansas and Oklahoma.

The benefits in SPP above are summarized in tables 17 and 18 below:

**Table 17: Summary of Benefits of Incremental 2,670 MW of Renewables (1/2)**

Annual Renewables Benefits			Notes
Additional Generation	New Wind	8,640 GWh	Wind assumes 37.5% capacity factor, solar assumes 18.0% capacity factor.
	New Solar	60 GWh	
	Total	8,700 GWh	
Reduction in Curtailment from Existing Wind		76 GWh	
Total Increase in Renewable Generation		8,776 GWh	
Annual Production Costs Savings		\$175 million	
Annual Carbon Reduction		3 million tons	Assumes Combined Cycle Plant (350g per kWh).

**Table 18: Summary of Benefits of Incremental 2,670 MW of Renewables (2/2)**

Renewables Benefits		
Direct Jobs from Renewables	Short-term (Construction etc)	Over 11,300 person-year
	Long-term (O&M etc)	Over 650 person-year
Estimated Local Tax Revenues (Annual)		\$32 million

**Estimated Land Lease Revenues (Annual)**

**\$15 million**

### **Potential Nation-Wide Benefits of GETS**

GETs deployment can also generate significant benefits on a national scale. To estimate GETs-enabled additional renewable integration at the national level, we begin by noting 2019 generation in Kansas and Oklahoma combined was about 136 Terrawatt-hours (TWh) [6]. 8,700 GWh from the GETs enabled new renewable generation equates to 6.4% of 136 TWh. The nationwide generation from utility-scale resources in 2019 was about 4,100 TWh; therefore, 6.4% of 4,100 TWh would equate to 260 TWh worth of clean power.

We estimate nation-wide GETs investment costs to be \$2.7 billion (only for the first year) and estimate ongoing costs to be around \$300 million per year. Extrapolating these results to a nation-wide level indicate that GETs can provide annual benefits in the range of:

- Over \$5 billion (~\$5.3 billion) in production cost savings.
- 90 million tons of reduced carbon emissions, assuming wind replaces natural gas burning combined cycle plants – the cleanest conventional fossil-fuel-based power generation technology. This reduction is more than enough to offset emissions from all new automobiles sold in the U.S. in a year.
- About \$1.5 billion in local benefits (local taxes and land lease revenues).
- More than 330,000 short-term (only for the first year) and nearly 20,000 long-term jobs.

It should be noted that the benefits calculated here do not vary by market structure—these savings metrics are relevant to both utilities that are still vertically integrated and those that are under deregulated RTO/ISO wholesale markets.

### **IV. Conclusion**

GETs are capable of quickly and cost-effectively maximizing the capability of the existing transmission system and can provide benefits at both the local and national levels. We estimate that the combined deployment of DLR, Advanced Power Flow Control, and Topology Optimization can double the amount of annual renewable development (an increase of 2,670 MW) in Kansas and Oklahoma in 2025 relative to a base case with no GETs deployment. At installation and annual O&M costs of \$90 million and \$10 million, respectively, GETs deployment in SPP is estimated to generate \$175 million in annual production cost savings, suggesting a pay-back period of half a year. Additional benefits include: 11,300 direct short- jobs and over 650 direct long-term jobs, \$32 million in annual tax revenues and \$15 million in land lease revenues, and carbon emissions reductions estimated to total over 3 million tons per year. We find these benefits to increase significantly as we extrapolate these findings to the national level.

## BIBLIOGRAPHY

Type here the bibliography at the end of your text, according to this presentation (see sample references below). Font to be used is always Times or Helvetica 11 or 12.

- [1] SPP, “GI Active Requests,” Accessed September 28, 2020, available at: <https://opsportal.spp.org/Studies/GIActive>.
- [2] SPP, *2019 Integrated Transmission Planning Assessment Report*, November 6, 2019, available at: [https://spp.org/Documents/60937/2019%20ITP%20Report\\_v1.0.pdf](https://spp.org/Documents/60937/2019%20ITP%20Report_v1.0.pdf), and SPP, *Quarterly Project Tracking Report*, available at: <https://www.spp.org/documents/62710/q3%202020%20qpt%20report%20draft.pdf>.
- [3] U.S. Department of Energy, *Dynamic Line Rating Systems for Transmission Lines: Topical Report*, April 25, 2014, available at: [https://www.energy.gov/sites/prod/files/2016/10/f34/SGDP\\_Transmission\\_DLR\\_Topical\\_Report\\_04-25-14.pdf](https://www.energy.gov/sites/prod/files/2016/10/f34/SGDP_Transmission_DLR_Topical_Report_04-25-14.pdf).
- [4] SPP, *LP&L Exit Study: Comprehensive Assessment*, June 30, 2017, available at: [https://www.spp.org/documents/52338/2017-lpl%20exit%20study%20-%2020170630\\_final.pdf](https://www.spp.org/documents/52338/2017-lpl%20exit%20study%20-%2020170630_final.pdf).
- [5] SPP, *State of the Market 2019*, May 11, 2020, available at: <https://www.spp.org/documents/62150/2019%20annual%20state%20of%20the%20market%20report.pdf>.
- [6] EIA shows 2019 generation in Kansas and Oklahoma combined (136 TWh) was about 1/30 of the nationwide generation from utility-scale resources (4,100 TWh). EIA, “Kansas Electricity Profile 2019,” November 2, 2020, available at: <https://www.eia.gov/electricity/state/kansas/>, EIA, “Oklahoma Electricity Profile 2019,” November 2, 2020, available at: <https://www.eia.gov/electricity/state/oklahoma/>; EIA, “Table 1.1. Total Electric Power Industry Summary Statistics, 2019 and 2018,” (n.d.), available at: [https://www.eia.gov/electricity/annual/html/epa\\_01\\_01.html](https://www.eia.gov/electricity/annual/html/epa_01_01.html).