

INTERNAL

HITACHI
Inspire the Next

System Impacts of an Electric Fleet Cluster on the Distribution Grid

Shyamal Patel, Senior Consultant - Hitachi Energy

CIGRE GOTF Conference

National Grid

© Hitachi Energy 2021. All rights reserved.

 **Hitachi Energy**

Acknowledgement of people who contributed to this study:

National Grid:


Gideon Katsh
Jeffrey Wilke
John McDaniel
Kelly Stropp
Brian Yung
Kaitlyn Meyer
Brian Johnson

Hitachi Energy:

Jonathan Hou
Shyamal Patel
Gary Rackliffe
Michael Ziemann
Christian Pierce

Previous CIGRE publications:


- Sensitivity analysis of the fleet charging impact on feeder load.
- Impacts of Fleet Electrification on Grid Infrastructure



- Introduction: Fleet electrification
- Methodology: Overview of Fleet Charging Load Modelling
- Case Study: Overview
- Impact Analysis: Feeder Overload, Undervoltage, Active power losses, Substation overload, transmission line impacts
- Mitigation options
- Conclusions

Motivation for the fleet electrification

- Medium and heavy-duty vehicles GHG contribution → 23%*
- Push to decarbonize of the transportation sector.
- Fifteen states and the District of Columbia have pledged for 100% zero-emission MHDV sales by 2050 (30% by 2030) with 37 businesses issuing letters of support.
- Fleets offer a substantial return on investment when it comes to decarbonization.






*Nadel, S., and P. Huether. 2021. Electrifying Trucks: From Delivery Vans to Buses to 18-Wheelers. Washington, DC: American Council for an Energy-Efficient Economy. www.aceee.org/research-report/t2102

Methodology: Overview of Fleet Charging Load Modeling

Monte Carlo simulation
used to evaluate fleet
schedules

Fleet schedules used to
develop charging profiles

Charging profiles mapped
to nearest feeder and
aggregated to determine
load impact



Variables for each vehicle's
trip → start time, duration,
and distance traveled


Charging profiles dependent on:

- Seasons: Summer and Winter
- Charging Strategies: Full Charging & Minimum Charging
- Fleet Type: Class 3-8


51 Fleets mapped to 19 Feeders:

- Load impact determined for the various charging profiles of each fleet

Feeders supporting major fleet operators




Load profiles with fleet charging load




© Hitachi Energy 2021. All rights reserved.


Fleet locations on feeder 18



Case Study: Overview

- Feeder 18 shares the substation transformer with 3 additional feeders.
- Feeder voltage level: 13.2 kV
- Rated capacity of the feeder:
 - 8.2 MW (Summer)
 - 9.85 MW (Winter)
- Current peak feeder loading: ~2 MW
- Existing and upcoming DERs: 5 MW PV + Storage
- Forecasted Fleet load at 100% electrification: ~25 MW (for 10 Fleets with >400)
- Forecasted Public Charging Load: 0.32 KW
- Forecasted residential charging load: 0.3 KW






Impact Analysis Results: Feeder Overload

- Currently, the feeder is lightly loaded with 2MW of the commercial and industrial loads and does not experience any immediate thermal violations.
- At 33% EV penetration, 88 sections are violated with a total length of 2.4 miles.
- At 100% EV penetration, all upstream sections (total length of 4.72 miles) violate the thermal limits by >444%.

Table: Feeder overload for increasing EV penetration level

Penetration level	Affected length (miles)	Overload %
33%	2.42	Up to 209%
67%	3.82	Up to 364%
100%	4.72	Up to 444%
133%	4.72	Up to 544%



- Feeder 18 has no downstream voltage regulating device.
- The feeder head voltage recommended level is 1.025 pu.
- The voltage violations are observed at selected downstream nodes for 33% level EV penetration. This voltage drops can be regulated using regulators or capacitors.
- Voltage dips below 0.9 pu for >67% EV penetration on majority of the feeder nodes. This voltage dip cannot not be improved through the voltage regulating device.
- The lower voltages on the distribution system
➔Higher losses







Table 5: Impact of increasing EV penetration level on feeder node voltages		
Penetration level	Affected Nodes	Undervoltage %
33%	149	0.92
67%	328	0.85
100%	352	0.79
133%	365	0.73



Variation in System Losses with Increasing EV Penetration	
Penetration Level	Loss (kW)
0%	19
33%	555
67%	2,169
100%	2,697
133%	4,150

- The existing location of the fleets is agnostic of the grid impacts at 100% electrification of vehicles. Hence, the fleet charging near the feeder end may contribute to higher loss than those near the feeder-head.
- The contribution to the total system losses from the fleets can range from 1.5 to 7.5%.
- The losses further increases with the increasing adoption of EVs due to higher voltage drops.

Substation Impacts





- Substation transformer experiences the overload EV penetration of 67%.
- At 100% EV penetration, all substation devices are expected to violate the thermal ratings, thereby indicating a requirement to plan for the upgrade to address the increasing EV penetration.

Impact of fleet charging load on the substation device loading						
Device	Device Ratings	Overload (%)				
Penetration Level		0%	33%	67%	100%	133%
CT1	1,200 A	55.8	92.5	129.2	167.0	203.7
CT2	2,000 A	33.5	55.5	77.5	100.2	122.2
CT3	2,000 A	33.5	55.5	77.5	100.2	122.2
CT4	1,500 A	44.6	74.0	103.4	133.6	163.0
CT5	1,500 A	44.6	74.0	103.4	133.6	163.0
CT6	2,000 A	33.5	55.5	77.5	100.2	122.2
CT7	600 A	14.4	74.8	135.1	197.3	257.6
CT8	600 A	14.4	74.8	135.1	197.3	257.6
T1	37,000 kVA	43.2	71.7	100.2	129.5	157.9
B1	2,000 A	33.5	55.5	77.5	100.2	122.2
B2	1,200 A	7.2	37.4	67.6	98.7	128.8
BB1	2,000 A	33.5	55.5	77.5	100.2	122.2

Transmission Level Impacts

- The transmission impacts of EV adoption covering the entire study area were studied under various scenarios to identify N-1 and N-1-1 violations.
- The solutions required for the N-1 violations included the replacement of a current transformer, reconductoring of roughly half a mile of an overhead transmission line and its station connections, and operational changes to prevent further upgrades.
- The solutions required for the N-1-1 violations included reconductoring of multiple miles of both overhead and underground transmission lines, reconductoring of specific station connections, and multiple operational changes to prevent further upgrades.





- Due to the tendency of fleets to “cluster” in industrial areas, load impacts from fleet electrification will be felt acutely at certain areas of the grid.
- Even early stages of fleet electrification could introduce substantial amounts of new electric demand to these areas: at 33% adoption of electric vehicles, peak electric demand in the case study area would more than quadruple.
- At that point, almost half the 5-mile distribution circuit would be overloaded, with some sections reaching 150% of their rating. At higher levels of penetration, the substation components will face overload, as well.
- A mitigation strategy is required to prepare the grids for large scale electrification of the automobile sector. It will be valuable to consider: the time required to implement a given solution; the pace of electrification; cost; and the likelihood of requiring additional upgrades in the future.



HITACHI
Inspire the Next 