



Pipeline Considerations for New and Repurposed Pipelines:


Conversion for Pure H₂ Pipelines and Blended NG/H₂ Pipelines

Speaker: Andrew López


Company: Burns & McDonnell

Summary

- ▶ Guidance for introducing hydrogen into pipelines
- ▶ ASME B31.12-2019 & ASME B31.8-2022 for hydrogen systems
- ▶ Inspection, testing, and anomalies
- ▶ Wall thickness determination and MAOP




Is this guy at the wrong conference?




Relevant Code

- ▶ ASME B31.8-2022 for hydrogen in hydrocarbon mixtures
 - No upper limit in code, but pure H₂ excluded in scope
 - ASME B31.8 is incorporated by reference in 49 CFR Part 192 [1]
- ▶ ASME B31.12-2019 for pure hydrogen
 - Minimum 10% hydrogen
 - More conservative calculations
- ▶ Clarifications on code scope within ASME B31 Committee



Conversion of Existing Pipelines

- ▶ Behavior of blended hydrogen systems
- ▶ Hydrogen-induced damage factors




*Image courtesy of Ken Lee (DNV GL), permission provided via email Friday, August 4, 2023 2:13 pm




Blended Hydrogen Systems

- ▶ Safety evidence for up to 25% hydrogen*
- ▶ Grades suitable for blended hydrogen
- ▶ Anomaly identification through smart pigging




SYNTHETIC NATURAL GAS (SNG)

Up to 15 % Hydrogen!



Pure Hydrogen Systems

- ▶ Hydrogen embrittlement/attack
- ▶ Inspection and anomaly records
- ▶ All threaded and flanged connections should be inspected for potential leaks.
- ▶ Existing or historic pipeline defects that can be embrittled by H₂
 - Axial cracks
 - Circumferential cracks
 - Internal surface-breaking defects
 - Pipe seam defects, e.g., hook cracks and lack of weld seam fusion
 - Hard spots
 - Welds with defects or high hardness



[9] Del-Pozo, Villalobos, Serna

Material Specifications & Selection

- ▶ Metallurgical reactions with hydrogen
- ▶ Lower-grade materials for prevention
- ▶ Piping material performance factor (M_f)
- ▶ Pipeline material performance factor (H_f)

Table IX-5B Carbon Steel Piping Materials Performance Factor, M_f

Specified Min. Strength, ksi		System Design Pressure, psig					
Tensile	Yield	≤1,000	2,000	3,000	4,000	5,000	6,000
70 and under	≤52	1.0	0.948	0.912	0.884	0.860	0.839
Over 70 through 75	≤56	0.930	0.881	0.848	0.824	0.800	0.778
Over 75 through 80	≤65	0.839	0.796	0.766	0.745	0.724	0.706
Over 80 through 90	≤80	0.715	0.678	0.645	0.633	0.618	0.600

Specified Min. Strength, ksi		System Design Pressure, psig						
Tensile	Yield	≤1,000	2,000	2,200	2,400	2,600	2,800	3,000
66 and under	≤52	1.0	1.0	0.954	0.910	0.880	0.840	0.780
Over 66 through 75	≤60	0.874	0.874	0.834	0.796	0.770	0.734	0.682
Over 75 through 82	≤70	0.776	0.776	0.742	0.706	0.684	0.652	0.606
Over 82 through 90	≤80	0.694	0.694	0.662	0.632	0.610	0.584	0.542

**Table PL-3.7.1-2 Basic Design Factor, F
(Used With Option B)**

Location Class	Design Factor, F
Location Class 1, Division 2	0.72
Location Class 2	0.60
Location Class 3	0.50
Location Class 4	0.40

Table PL-3.7.1-3 Temperature Derating Factor, T , for Steel Pipe

Temperature, °F	Temperature Derating Factor, T
250 or less	1.000
300	0.967
350	0.933
400	0.900
450	0.867

GENERAL NOTE: For intermediate temperatures, interpolate for derating factor.

Example Calculations

- ▶ Wall thickness calculations for various grades
- ▶ ASME B31.12 vs. ASME B31.8
 - B31.12 has separate calculations for piping and pipelines

Table 1 – B31.12 Wall Thickness for 42" Piping @ 1400 psig up to 300 °F

Grade	Wall Thickness
X42	1.535"
X52	1.399"
X56	1.397"
X60	1.456"
X65	1.426"
X70	1.571"
X80	1.434"

Table 3 - B31.12 Wall Thickness for 42" Pipeline @ 1400 psig up to 300 °F

Grade	Wall Thickness
X42	2.195"
X52	2.014"
X56	2.127"
X60	2.027"
X65	2.200"
X70	2.084"
X80	2.117"

Table 5 - B31.8 Wall Thickness for 42" Pipe @ 1400 psig up to 300 °F

Grade	Wall Thickness
X42	1.167"
X52	0.9423"
X56	0.875"
X60	0.817"
X65	0.754"
X70	0.700"
X80	0.613"

Calculations, continued

- ▶ Wall thickness calculations for various grades
- ▶ ASME B31.12 vs. ASME B31.8
 - B31.12 has separate calculations for piping and pipelines

Table 2 - B31.12 Wall Thickness for 30" Piping @ 1400 psig up to 300 °F

Grade	Wall Thickness
X42	1.096"
X52	0.999"
X56	0.998"
X60	1.046"
X65	1.019"
X70	1.122"
X80	1.024"

Table 4 - B31.12 Wall Thickness for 30" Pipeline @ 1400 psig up to 300 °F

Grade	Wall Thickness
X42	1.568"
X52	1.439"
X56	1.519"
X60	1.448"
X65	1.572"
X70	1.489"
X80	1.512"

Table 6 - B31.8 Wall Thickness for 30" Pipe @ 1400 psig up to 300 °F

Grade	Wall Thickness
X42	0.834"
X52	0.674"
X56	0.625"
X60	0.584"
X65	0.539"
X70	0.500"
X80	0.438"

Seriously? More...

► Repurposing a 1400 psig Natural Gas line

Table 6 - B31.8 Wall Thickness for 30" Pipe @ 1400 psig up to 300 °F

Grade	Wall Thickness
X42	0.834"
X52	0.674"
X56	0.625"
X60	0.584"
X65	0.539"
X70	0.500"
X80	0.438"

→ 430 psig

Table 5 - B31.8 Wall Thickness for 42" Pipe @ 1400 psig up to 300 °F

Grade	Wall Thickness
X42	1.167"
X52	0.9423"
X56	0.875"
X60	0.817"
X65	0.754"
X70	0.700"
X80	0.613"

→ 430 psig

Conclusion

- ▶ Blending hydrogen in existing pipelines up to 25%
- ▶ Analysis for pure hydrogen conversion
- ▶ Considerations for new hydrogen pipelines

- ▶ Keywords
 - Hydrogen Pipelines
 - Blended Natural Gas
 - Net Zero Carbon Economy

Q&A

